

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-22-11-23-02

Product: "MMF floor covering", Thickness: 5 mm
Structures: New England (NE), Peetah (PT), Hickory Scrape (HS)

Producer: Kronoflooring Sp. z o.o., ul. Przemysłowa 10, 38-200 Jasło, Poland

Order: Testing and classification of selected properties
according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling)

Test reports: 2719075/3, 2718587, 2719250

Test results:

| Property | Declaration according to EN 14041:2004+AC:2005+AC:2006 |
|--|---|
| Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, classification according to EN 13501-1 | Fire Class B _{ff} -s1* |
| Anti-sliding properties according to EN 13893 | Class DS |
| Thermal resistance according to EN 12667 | 0,01 (m ² K)/W |

* Valid on mineral subfloor in end use application, using adhesives or not.

Dresden, 23/11/2022

Head of laboratory



Engineer in charge