

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-21-11-26-01

Product: MMF floor covering with structure FN

Client: Kronoflooring Sp. z o.o.
ul. Przemysłowa 10
38-200 JASŁO
POLEN

Order: Determination of the anti-sliding property according to EN 13893:2002-11 /
Classification according to EN 14041:2004+AC:2005+AC:2006

Test report: 2721545

Test results: The above mentioned product can be classified regarding to the tested property
„Anti-sliding property“ according to EN 14041:2004+AC:2005+AC:2006
(CE-labelling) as follows:

Property	Determined value	Declaration according to EN 14041:2004 + AC:2005 +AC:2006
Anti-sliding property according to EN 13893:2002-11	$\mu = 0,57$	class DS

Dresden, 26/11/2021

R. Emmerich

Head of laboratory



S. V. Pusch

Engineer in charge