

T E S T C E R T I F I C A T E

ST-21-11-26-01

Product: MMF floor covering with structure FN

Client: Kronoflooring Sp. z o.o.
ul. Przemysłowa 10
38-200 JASŁO
POLEN

Order: Determination of the anti-slip properties according to DIN 51130:2014-02

Test report: 2721545

Test result:


Property	Result	Anti-slip class according to DIN 51130:2014-02
Anti-slip resistance according to DIN 51130:2014-02	$\alpha_{ges} = 14,9^\circ$	R10

α_{ges} ... Total acceptance angle

Dresden, 26/11/2021



Head of laboratory



Engineer in charge