

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-23-03-13-01

Product: MMF floor coverings with iXPE Underlayment
Thickness: 5 + 1 (mm) and 4 + 1 (mm)

Producer: Kronoflooring Sp. z o.o., ul. Przemysłowa 10, 38-200 Jasło, Poland

Order: Determination of the thermal conductivity and thermal resistance according to EN 14041:2004+AC:2005+AC:2006 and EN 12667:2001

Test report: Test Report no. 2623014, dated 13/03/2023

Results:

Product names	Thermal conductivity $\lambda^{10}_{23/50}$ [W/(m*K)]	Thermal resistance $R^{10}_{23/50}$ [(m ² K)/W]	Declaration according to EN 14041:2004 +AC:2005+AC:2006
MMF Floor Covering with iXPE Underlayment, 5 + 1 mm thick	0,229	0,0249	0,23 W/(m*K) 0,025 (m ² K)/W
MMF Floor Covering with iXPE Underlayment, 4 + 1 mm thick	0,179	0,0282	0,18 W/(m*K) 0,028 (m ² K)/W

Dresden, 13/03/2023



Head of laboratory




Engineer in charge