

# T E S T C E R T I F I C A T E

ST-23-10-26-02

**Product:** MMF floor covering and wall covering with structure PT

**Producer:** Kronoflooring Sp. z o.o.  
ul. Przemysłowa 10  
38-200 Jasło  
Poland

**Order:** Determination of slip resistance of floor coverings - Methods of evaluation according to EN 16165:2021-10, Annex B (Shod ramp test - walking on an inclinable walkway)

**Test Report:** 2723564

**Test Result:**

Property	Anti-Slip Class according to EN 16165:2022-02, National Annex NB (informative), Table NB.2
Slip resistance of floor coverings - Methods of evaluation according to EN 16165:2021-10, Annex B (Shod ramp test - walking on an inclinable walkway)	R9

Dresden, 26/10/2023



Head of laboratory




Engineer in charge