

4. Classification and field of application

4.1. Reference of classification

This classification has been carried out in accordance with EN 13501-1:2018.

4.2. Classification

The product, „ Wall covering - type I”, in relations to its reaction to fire behaviour is classified:

C

The additional classification in relations to smoke production is:

s2

The additional classification in relations to flaming droplets / particles is:

d0

The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation products is:

Fire behaviour		Smoke production			Flaming droplets	
C	-	s	2	,	d	0

Reaction to fire classification: C-s2,d0